

Published by Friends of the Earth

Radiation Weakens Pressure Vessels

The Nuclear Regulatory Commission (NRC) has become increasingly concerned about one of the most serious potential accidents in a nuclear reactor. Early in July, the agency released a list of 14 pressurized water reactors (PWR) that have

become especially prone to pressure vessel rupture, an accident that one senior NRC official said would create "a 50-50 chance of an uncontrolled nuclear meltdown."

Pressure vessel rupture is such an extraordinarily disabling accident that it would

probably prevent any system, including the emergency core cooling system (ECCS) from cooling the core. The Nuclear Regulatory Commission's concern is that pressurized water reactors aged three to ten years have vessels that have become unexpectedly brittle from intense neutron radiation over their lives. Brittleness is especially troublesome at high pressure and low temperatures, and can cause a pressure vessel to crack like hot glass dunked in cold water.

A number of accidents can cause pressure vessels to rupture. The gravest danger generally caused by a small water leak is the primary or secondary reactor cooling system. This results in a prompt decrease in pressure in the system, and operators turn to the emergency core cooling system to rapidly reduce temperatures and prevent formation of any steam in the system. The Three Mile Island accident was caused when reactor operators prematurely turned off the emergency system, mistakenly guessing that the primary system had "gone solid" because water was being released from the pressure relief valve in the plant's pressurizer. One official told NRC in the aftermath of the accident, "They probably did it to prevent overpressurization."

The Narrow Line Between Cooling and Cracking

Overpressurization and pressure vessel rupture are precisely the NRC's current concerns, creating a contradictory situation for PWR operators: on one hand, they must keep the ECCS on long enough to absolutely certain the primary system is solid; on the other hand, they must ensure the ECCS is not on so long that the pressure vessel cools too rapidly and cracks. The penalty for failing to walk this narrow line is meltdown either way—from preventing reactor cooling and secondarily from cooling it too much.

Since 1973, there have been 13 serious "overcooling" or overpressurization accidents, the most famous of which is the Rancho Seco light bulb accident in March 1978. The accident, which tops every other California light bulb joke, happened when a repairman unscrewing a light bulb dropped it behind the reactor control panel, thereby shorting out the plant's integrated control system (ICS). The ICS mistakenly indicated catastrophic reactor conditions on non-functioning gauges, and the reactor steam generator tripped, activating the emergency core cooling system.

The first stage of this system, the Fast Pressure Injection System, cooled the reactor core at a rate of 300°F per hour, 200°F per hour faster than NRC regulations permit. The pressure vessel was severely overcooled as a result.

The Department of Energy's Oak Ridge National Laboratory recently reported that the probability of a pressure vessel burst at Rancho Seco "would have been very high" if the reactor had been operating at full power for ten years at the time of the 1978 accident. Fortunately, it had only been operating at full power for four years

Brittle Bones at Such A Tender Age!

Long periods of reactor operation result in substantial radiation exposure to the steel in a pressure vessel. A new pressure vessel can withstand temperatures of 0-40°F at high pressures without becoming so brittle that it would crack. As a reactor ages, however, the six to twelve-inch-thick steel vessels become "embrittled"—they become less resistant to fracture at progressively higher temperatures. According to the NRC, three reactors have pressure vessels that become brittle at 250-280°F. These are the San Onofre 1 reactor, Robinson 2, and Fort Calhoun; they began commercial operation in 1968, 1971, and 1973, respectively. Thirteen is a young age for brittle bones. The cost-benefit analysis prepared to justify construction of these plants assumed 30 to 40 years of trouble-free operation.

"I think we've got a year, most of the staff would probably say five," noted one senior NRC safety official. "We know [these plants] are not going to last their full design lifetimes."

All three manufacturers of pressurized water reactors admit the seriousness of the problem. In a May 1981 report to the NRC, Westinghouse states that its most vulnerable reactors can withstand a severe overcooling accident through January 1983. Combustion Engineering reports that its reactors would last at full power for five more years at twice the predicted embrittlement rates before vessel strength becomes a problem. Babcock & Wilcox reports that there is "no immediate problem" between now and 1983, "given operator action" *not to repressurize the vessel*. Combustion Engineering has found that embrittlement at the Maine Yankee power plant is occurring 2.3 times faster than they expected.

The normal operating temperature inside the pressure vessel is 600°F. At this temperature, embrittlement poses no problem. But with a rapid drop in coolant temperature, caused by a very common scram or transient, the pressure vessel's insides try to contract. The outside of the six and a half inch vessel is still very hot, and the temperature differential creates enormous tensile stresses.

It was precisely this concern, that led Britain's chief science advisor, metallurgist Sir Alan Cottrell, to recommend against the purchase of 22 Westinghouse reactors for that nation in 1974. The American Physical Society also raised this concern in their report on reactor safety in summer 1975. But APS dismissed the "British" concern, noting that "current steels for reactor pressure vessels are rather insensitive to radiation embrittlement. . . it is estimated that no substantial embrittlement will occur during the assumed 40-year life of the pressure vessel." The APS expressed graver concern for embrittlement in primary coolant system piping, a problem that has already occurred.

Some Possible Scenarios

Pressure vessels are commonly used in coal power plants, but leaks in the vessels give away the location of cracks. In the much thicker vessels, leaks do not occur until it is far too late to prevent disaster. It is not clear exactly what would happen if a pressure vessel were to crack from overcooling, but several things are possible. In a small rupture, it would be impossible to keep the reactor at a high enough pressure to prevent steam from forming inside the vessel. Forcing ECCS water into the core and "squeezing" the steam bubble—as was done at TMI—would not be possible, because higher pressures would force more and more water out of the pressure vessel. The core would then melt its way through the bottom of the pressure vessel, and start down the road to China. A large rupture would merely be worse.

All the pressurized water reactors (PWR) in the nation—44 total—are subject to vessel rupture. The NRC has found evidence of serious embrittlement in 14 reactors, including the three named above, plus Maine Yankee (200-300°F), Palisades (190-220°F), Yankee Rowe (180-210°F), Oconee 1 (160-190°F), Zion 1 (150-180°F), Arkansas 1 (150-180°F), Indian Point 2 (150-180°F), TMI 1 (140-170°F), Rancho Seco (130-160°F), Surry 1 (120-150°F), and Crystal River 3 (110-140°F). Babcock & Wilcox PWRs are particularly prone to overpressurization accidents, but all PWRs are possible candidates.

Very little can be done to forestall or avoid the problem; it is a process of aging. A number of fuel elements can be removed from the outside of the reactor core and operating temperatures can be reduced; this simply slows the rate of embrittlement

and substantially reduces the output of the reactor. Thermal "annealing" is the other option; in this process the pressure vessel is heated several hundred degrees above normal operating temperatures with an exterior heat source for extended periods of time. No large vessel has ever been annealed; a small Army reactor was annealed twelve years ago, with modest, but not complete success.

It is one of the most serious problems faced by the nuclear industry, and it has no obvious technical "fix."

Sources: *Science News*, June 20, 1981; *San Diego Union*, July 9, 1981 (sent by Jim Jacobson); American Physical Society report on light water reactor safety (Panofsky, Weisskopf, Bethe, Lewis, *et al.*), summer 1975; letter from Demetrios Basdekas to Morris Udall, April 1981.